




RIGHT SIDE VIEW



END VIEW



SECTION A-A



EMBEDMENT DETAIL

NOTES:

- 1. MANHOLE STEPS: CAPABLE OF WITHSTANDING A SINGLE CONCENTRATED LOAD OF 300 POUNDS APPLIED AT A DISTANCE OF 5 INCHES FROM THE FACE OF THE STRUCTURE WALL.
- 2. STEPS ARE TO BE VERTICALLY ALIGNED AND UNIFORMLY SPACED WITH A MINIMUM SPACING OF 12 INCHES AND A MAXIMUM SPACING OF 16 INCHES UNLESS SHOWN OTHERWISE ON STRUCTURE PLANS.
- 3. USE EITHER MANHOLE STEPS CAST-IN-PLACE, OR GROUTED INTO STRUCTURE WALL IN SUCH A MANNER AS TO PREVENT PULLOUT UNDER A LOAD OF 300 POUNDS APPLIED 5 INCHES FROM THE FACE OF THE STRUCTURE WALL.
- 4. STEEL REINFORCING OF MANHOLE STEPS: CONFORM TO AASHTO DESIGNATION M 31, GRADE 60, DEFORMED STEEL BAR. PLASTIC COATING OF MANHOLE STEPS: CONFORM TO ASTM DESIGNATION D 2146, TYPE II, GRADE 16906.
- 5. MANHOLE STEPS: CONFORM TO AASHTO DESIGNATION M 199 UNLESS NOTED OTHERWISE.6. DIMENSIONS MAY VARY WITH MANUFACTURES DESIGN. USE ALTERNATIVE DESIGN WITH THE APPROVAL OF THE ENGINEER.

							NO. DATE APPR. REMARKS	
							NO.	
UTAH DEPARTMENT OF TRANSPORTATION	STANDARD DRAWINGS FOR ROAD AND BRIDGE CONSTRUCTION	SALT LAKE CITY, UTAH	ECOMMENDED FOR APPROVAL	JULY 83,2882	CHAIRMAN STANDARDS COMMITTEE	JULY 03,2002	DEPUTY DIRECTOR DATE DATE	
			 MANHULE SIERS	WG			STANDARD DRAWING TITLE	